

General Disclaimer

One or more of the Following Statements may affect this Document

- This document has been reproduced from the best copy furnished by the organizational source. It is being released in the interest of making available as much information as possible.
- This document may contain data, which exceeds the sheet parameters. It was furnished in this condition by the organizational source and is the best copy available.
- This document may contain tone-on-tone or color graphs, charts and/or pictures, which have been reproduced in black and white.
- This document is paginated as submitted by the original source.
- Portions of this document are not fully legible due to the historical nature of some of the material. However, it is the best reproduction available from the original submission.

(NASA-TM-X-73209) AN INFRARED FOREOPTICS
ADAPTOR FOR THE LEARJET TELESCOPE (NASA)
12 p HC A02/EF A01 CSCL Q3A

N77-17576

Unclas
G3/89 16281

NASA TECHNICAL
MEMORANDUM

NASA TM X- 73,209

NASA TM X- 73,209

AN INFRARED FOREOPTICS ADAPTOR FOR THE LEARJET
TELESCOPE

E. F. Erickson and G. Buck

Ames Research Center
Moffett Field, California 94035

February 1977



1. Report No. NASA TM X-73,209	2. Government Accession No.	3. Recipient's Catalog No.	
4. Title and Subtitle AN INFRARED FOREOPTICS ADAPTOR FOR THE LEARJET TELESCOPE		5. Report Date	
		6. Performing Organization Code	
7. Author(s) E. F. Erickson and G. Buck*		8. Performing Organization Report No. A-6935	
9. Performing Organization Name and Address Ames Research Center, NASA Moffett Field, Calif. 94035		10. Work Unit No. 352-03-01-02	
		11. Contract or Grant No.	
12. Sponsoring Agency Name and Address National Aeronautics and Space Administration Washington, D. C. 20546		13. Type of Report and Period Covered Technical Memorandum	
		14. Sponsoring Agency Code	
15. Supplementary Notes *Contractor, Beam Engineering, Sunnyvale, Calif. 94087.			
16. Abstract A foreoptics adapter has been built for the Learjet Telescope which permits simultaneous viewing of the visible star field in the image plane and acquisition of astronomical data at infrared wavelengths (> 1 micrometer). The device uses an adjustable dichroic beamsplitter to transmit visible wavelengths to an eyepiece (or television camera), and to reflect infrared wavelengths to a port where an infrared detector system can be mounted. The instrument is intended as a multiple user facility for the Learjet Telescope. This report describes the adapter and its use.			
17. Key Words (Suggested by Author(s)) Astronomy		18. Distribution Statement Unlimited STAR Category - 89	
19. Security Classif. (of this report) Unclassified	20. Security Classif. (of this page) Unclassified	21. No. of Pages 10	22. Price* \$3.25

AN INFRARED FOREOPTICS ADAPTOR FOR THE LEARJET TELESCOPE

by

E. F. Erickson and G. Buck

NASA-Ames Research Center, Moffett Field, CA 94035

Abstract

A foreoptics adapter has been built for the Learjet Telescope which permits simultaneous viewing of the visible star field in the image plane and acquisition of astronomical data at infrared wavelengths (≈ 1 micrometer). The device uses an adjustable dichroic beamsplitter to transmit visible wavelengths to an eyepiece (or television camera), and to reflect infrared wavelengths to a port where an infrared detector system can be mounted. The instrument is intended as a multiple user facility for the Learjet Telescope. This report describes the adaptor and its use.

Summary

A foreoptics adapter has been built for the Learjet Telescope which permits simultaneous viewing of the visible star field in the image plane and acquisition of astronomical data at infrared wavelengths (\geq micrometer). The device uses an adjustable dichroic beamsplitter to transmit visible wavelengths to an eyepiece (or television camera), and to reflect infrared wavelengths to a port where an infrared detector system can be mounted. The instrument is intended as a multiple user facility for the Learjet Telescope. This report describes the adaptor and its use.

A cutaway view of the adaptor is shown in Figure 1. The nominal back focal distance (from the rear of the telescope backplate) is 230 mm, while the nominal distance from the face of the instrument mounting flange to the infrared focus is 70 mm. The reticle and eyepiece can be translated along the optical axis by ± 7 mm to optimize the visible focus once the telescope has been focussed for maximum infrared signal. Changing the back focal distance (reticle position) by more than ± 17 mm can be done by modifying the Eyepiece Extension or the Eyepiece Adaptor. The foreoptics with eyepiece weigh 1.6 kgm.

The dichroic beamsplitter has two micrometer adjustments to permit accurate alignment of the detector field of view with the secondary mirror of the telescope. These adjustments can be used to null infrared offset signals in flight as well. The beamsplitter is evaporated gold on glass. Its measured transmission and reflectivity are shown as a function of wavelength in Figure 2.

The foreoptics adaptor can be mounted either with the infrared beam horizontal or vertical, to accommodate either side-looking or down-looking detector cryostats. When side-looking dewars are employed, they should be mounted on the left (aft) side of the telescope axis, to counterbalance the weight of the finder telescope. A detail of the Instrument Mounting Flange is shown in Figure 3. Figure 4 shows a Suggested Instrument Mounting Adaptor which, when

bolted to the investigator's dewar, mates to the instrument mounting flange.

Two reticles are available, mounted in separate eyepiece adaptors. The two reticle patterns are shown in Figure 5. The smaller reticle is mounted with orthogonal position adjustments, and is shown in Figure 1. The larger reticle is fixed in its mount and is intended primarily for use with the fiber-optics bundle leading to the television camera. The reticle light circuit is shown in Figure 6. The reticle light power is provided by the telescope stabilization electronics.

It is recommended that the beamsplitter be kept clean by covering the instrument and telescope ports when not in use.

Reference: E.F. Erickson, D. Goorvitch, M.G. Dix, and M.J. Hitchman,

"Lear Jet Telescope System" NASA Technical Memorandum TM X-62,389.

Figures

1. Assembly drawing of the foreoptics showing pertinent optical distances.
2. Dichroic beamsplitter transmission and reflection as a function of wavelength.
3. Detail of the instrument mounting flange.
4. Suggested infrared detector mounting adaptor.
5. Available reticle patterns.
6. Reticle light circuit.




FIGURE 1

LEARJET TELESCOPE FOREOPTICS ASSEMBLY




FIGURE 2

SUGGESTED INSTRUMENT MOUNTING ADAPTOR

[MATES WITH INSTRUMENT MOUNTING FLANGE]




FIGURE 4

RETICLE PATTERNS




FIGURE 5

RETICLE LIGHT CIRCUIT




FIGURE 6